

VOC Content Test Certificate

Friday March 13th, 2009

Supplier: Architectural & Industrial Coatings

7 Lackey Road

Moss Vale NSW 2577

Sample Description: Envirothane 8470 water-based two part polyurethane coating

Date Tested: March 2009

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings.

Test Data:

<p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council of Australia Green Star Office Design V2 IEQ-13</p> <p style="text-align: center;">Green Star Office Interiors V1.1 IEQ-11</p>	<p style="text-align: center;">Envirothane 8470</p>
<p>Interior Gloss 75 grams per Litre maximum</p> <p>Exterior Gloss 75 grams per Litre maximum</p> <p>Exterior Semi-Gloss 70 grams per Litre maximum</p> <p>Exterior Low Flat Sheen 50 grams per Litre maximum</p>	<p style="text-align: center;">36 grams per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0903-12