

# VOC Content Test Certificate

**Date:** 14<sup>th</sup> November 2016

**Sample Description:** Enviroset 4111 Solvent Free Epoxy Coating

**Date Tested:** 14<sup>th</sup> November 2016

**Test Method:** APAS D181 6.1 a; Standard Practice for Determining Volatile Organic Compound (VOC)

Content of Paints and Related Coatings

**Test Data:**

<b>Specification</b>  Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 1EQ-11	Enviroset 4111 Solvent Free Epoxy Coating
One or Two Pack performance Coating for Floors 140 grams per Litre maximum	27 grams per Litre as VOC Content Material

Quality Assurance Manager: Giri Kuppaswamy

